

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 3550-0257:106 Page 1 of 1

**CATEGORY:** Door Closers/Holders

**LISTEE:** Yale, 1902 Airport Rd., Monroe, NC 28110  
Contact: \*Jeff Trull (704) 283-2101

**DESIGN:** Models 400, 3200BC, 3400BC and 3500 series with or without listee's separately listed integral smoke detector Model PTD-II (CSFM Listing No. 7256-0257:107). Refer to listee's data sheet for detailed product descriptions and operational considerations.

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as door closers/holders. These units may be interconnected to other listed combination door closers and holders with integral smoke detectors, to separately listed heat detectors, or to smoke detectors listed for releasing device service. When connected to any detector, a separately listed compatible control unit must also be used.

\*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**  
**Program Manager**